

Council ACP building information

Occupancy Type		Examples	ACP Cladding	
Category			Category	Definition
- Residential		Hotels, motels, halls of residence, apartments	ACP 1	Core 100% polyethylene (PE)
- Care facility		Hospitals, resthomes, medical facilities, early childhood centres	ACP 2	Core mineral fibre and some PE
- Public building		Library, cinema, shops, resturants, gyms, schools	ACP 3	Core mineral fibre
- Office		Offices, light industrial, warehouse (storage < 5m)		
- Industrial		Warehouse (storage > 5m)		
- Carparking		Carparking		

Building characteristics					ACP characteristics				
					Estimated percentage of total cladding (%)				
Year built	Approx height (m)	Number of storeys	Occupancy type	Sprinklered?	ACP 1	ACP 2	ACP 3	Noted from specifications	BWOF, NTF or infringement notice
1989	55	17	Residential	Yes		10%		Alucabond Plus	
2009	40	12	office	yes	25%			Alucobond PE	WOF54804 - Expire 01/04/2019 - No BWOF Audit - CSR92047643 - Notice to Fix closed 08/03/2017 - code compliance certificate issued
1970	35	11	Residential	Yes		5%		Alucabond plus Parapets fascia soffits	
2017	35	11	Residential	yes		5%		Larson® FR to fascia and soffits	
2016	32	8	Office	Yes	30%			Alucobond or equivalent aluminium faced composite panel with approved non-combustible fire rated core See 14/1450641	WOF56698 - Expire 01/10/2018 - No recent BWOF Audit - No Enforcement Actions Recorded
2017	30	9	Carpark and retail	Yes		5%		Reynobond Fire Rated to level 1 shopfront,	
2016	27	8	Car park	yes	5%			Kaneba ALUCOBOND® PE	WOF50840 - Expire 01/10/2018 - No BWOF Audit - CSR92047643 - Notice to Fix closed 08/11/2016 - "stop work" notice for BCN/2016/624830 - Infrngment Fines issued - 2008772 - \$1000 30:2008773 - \$1000
1974	25	7	Public building	Yes		10%		Alpolic or Alucobond ACM panel with noncombustable core	

2017	25	6	Care facility	Yes		25%		4mm thickness Alpolic aluminium composite material panel with non-combustible core	
1986	24	7	Residential	yes	5%			ALUCOBOND® PE	WOF52463 - Expire 01/04/2019 - No BWOFF Audit - No current Enforcement Actions Recorded
2015	24	6	Offices	Yes		15%		Apolic FR	
2017	22	5	Office	Yes	30%			Alucobond	WOF50282 - Expire 01/03/2019 - No BWOFF Audit - No current Enforcement Actions Recorded
2017	22	5	Office/retail	Yes		5%		ALUCOBOND PLUS-CORE ALUMINIUM COMPOSITE PANEL	
2014	21	5	Offices	Yes		20%		Aliclad	
1934	21	4	Office/retail	Yes	5%			4mm thick composite of aluminium and polyethylene eg. Alpolic, Alucobond	WOF52795 - Expire 01/09/2018 - No BWOFF Audit - No current Enforcement Actions Recorded
Construction not started	20	5	Office	No	5%			4mm Alucobond, or similar approved	WOF56416 - *CS Pre-issue with BCN/2014/5434 - No current Enforcement Actions Recorded
2016	20	5	office/retail	yes		50%		Alucobond Plus	
1989	20	5	office/retail	No		50%		Apolic f/r	
2010	19	5	Office	No	15%			Alucobond	WOF54161 - Expire 01/12/2018 - No BWOFF Audit - No current Enforcement Actions Recorded
2016	18	5	Office /retail	Yes	25%			Alucabond Kaneba	WOF51540 - Expire 01/04/2019 - No BWOFF Audit + WOF52964 - Expire 01/12/2018 - No BWOFF Audit - No current Enforcement Actions Recorded
1988	18	5	Office	Yes	15%			ALUCOBOND® PE	WOF50278 - Expire 01/08/2018 - No BWOFF Audit - No current Enforcement Actions Recorded
2016	18	4	Office	Yes		20%		Alucotex/FR	

2015	17	4	Office	Yes	10%			Kaneba Alucabond 4mm thick composite of aluminium and polyethylene	WOF53876 - Expire 01/06/2019 - No BWOA Audit - No current Enforcement Actions Recorded
2015	17	5	Office	Yes	20%			4251 ALUMINIUM COMPOSITE CLADDING	WOF52925 - Expire 01/01/2019 - No BWOA Audit - No current Enforcement Actions Recorded
2017	16	4	Office/retail	Yes		10%		ALUCOBOND® Plus	
2015	16	4	office	Yes	30%			4mm thick composite of aluminium and polyethylene e.g. Alpolic, Alucobond etc	WOF55975 - Expire 01/01/2019 - No BWOA Audit - No current Enforcement Actions Recorded
2017	16	4	Residential/office	yes		10%		Alucobond Plus	
2014	16	4	Office	No	15%			Kaneba™ ALUCOBOND® PE	WOF55705 - Expire 01/12/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2015	15	5	Office	Yes		10%		4mm thick composite of aluminium and polyethylene eg. Alpolic, Alucobond etc. Allow for Alpolic / fr MB106 Dark Grey Metallic (G30) and MJ062 Black (G30)	
2015	15	5	Office	Yes	20%			Kaneba™ ALUCOBOND® PE	WOF52267 - Expire 01/07/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2017	15	4	Office	Yes	50%			ALPOLIC OR SIMILAR APPROVED 4MM ALUMINIUM COMPOSITE PANEL CLADDING	WOF53189 - *CS Pre-issue with BCN/2015/1096 - No current Enforcement Actions Recorded
2016	15	4	Care facility	Yes	10%			Alucobond or Alpolic	WOF52520 - Expire 01/07/2018 - No BWOA Audit - EQ Prone Notice issued 31 May 2018.
2004	15	4	office/retail	yes	50%			Alucobond	WOF50221 - Expire 01/09/2018 - No BWOA Audit + WOF50661 - Expire 01/09/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2017	14	3	Office /retail	yes		30%		ACP type not specified	

2017	13	3	Office /retail	Yes	10%			Alucobond	WOF56422 - Expire 01/05/2019 - No BWOA Audit - No current Enforcement Actions Recorded
2017	13	3	Care facility	Yes		10%		Alpolic FR from Cudoclad	
2014	13	3	Office	No	20%			Kaneba™ ALUCOBOND® PE	WOF55614 - Expire 01/08/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2017	12	3	Residential	Yes		10%		Alucabond Plus	
2013	12	3	Office/retail	No	10%			Alucobond	WOF50048 - Expire 01/10/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2017	12	3	Office/retail	Yes	10%			Alucobond	WOF56115 - Expire 01/10/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2015	12	3	Office	Yes	10%			ALUCOBOND® PE,	WOF52504 - Expire 01/09/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2002	12	3	office/retail	yes	25%			PSP AlucoBuild	WOF53226 - Expire 01/04/2019
2017	11	3	Parking /Offices	Yes	20%			Keneba Alucabond	WOF56115 - Expire 01/10/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2015	11	3	Office	Yes	40%			4mm Aluminium Composite Panel (ACP) of external grade for cladding - Alucobuild?	WOF55954 - Expired on 01/06/2018 - No BWOA Audit - No current Enforcement Actions Recorded
2013	11	3	Office	No	25%			Kaneba™ ALUCOBOND® PE	WOF52072 - Expire 01/12/2018 - No BWOA Audit - No current Enforcement Actions Recorded
1980	10	3	Office	No	10%			Apolic parapet and soffit only	WOF53329 - Expire 01/01/2019 - No BWOA Audit - No current Enforcement Actions Recorded